



Piping Circuitization and Risk-Based Inspection Requirements

by Lynne Kaley, P.E.



- Materials/Corrosion and Risk Management Engineer
- 30 Years Refining, Petrochemical and Midstream Gas Processing Experience
- Leader in Risk-Based technology development for plant applications
- Project Manager of API RBI Joint Industry Project since 1996
- Member of API committees for development of API 580 and API 581 recommended practices
- Developer and Official Trainer for API 580/581 Public Training course
- Vice President and Principal Engineer with Equity Engineering

Purpose

- Purpose of Presentation
 - Using API 580 and 581 for piping Risk Assessment
 - Systemization and circuitization of piping
 - Understand complementary nature of Materials Operating Envelopes (MOE)
 - Understand challenges of piping inspection
- Sources
 - API RBI User Group Joint Industry Project
 - API 580
 - API 581
 - API 570
 - API 571
 - API RBI Software

Presentation Outline

- Introduction
- Piping Programs Characteristics
- Available Analysis Tools
- A Complementary Approach: Material Operating Envelopes (MOE)
- Piping Systemization and Circuitization
 - Piping study case study 1
 - Piping study case study 2
- Piping TML Data Analysis & Benefits
- Summary & Conclusions

The Goal

Assure regulatory and corporate compliance, and ensure reliable use of piping (and equipment) for finite run times, while measuring, managing and minimizing risks and eliminating non-value adding activities and costs.

Introduction

- Historical industry statistics attribute piping failure to be leading cause of large property losses
- Industry data indicates that the most frequent unexpected failures occur in piping systems (30-45%) due to localized corrosion, often by undetected mechanisms
- The majority of industry piping programs use a classification system from API 570 for criticality ranking
- Straight beam ultrasonic inspection (UT) is the most commonly used method for thinning damage detection
- Quality of inspection data, coverage of inspection points and a link of inspection locations and type to damage mechanism must be analyzed to assure program effectiveness
- Correct CML/TML placement needs to be determined in conjunction with active damage mechanisms identified by experienced corrosion/materials engineer

Introduction

- *"Losses in the refinery industry have continued to increase over the last few years and the causes highlight the aging facilities in this category. A significant number of larger losses (over \$10,000,000) have been caused by piping failures or piping leaks, leading to fires and/or explosions. Several large losses due to piping failures were due to corrosion issues or using the wrong metallurgy....."*

From the Marsh and McLennan Report, *The 100 Largest Losses 1972-2001*, 20th Edition: February 2003, a publication of Marsh's Risk Consulting Practice

Introduction

The explosion occurred when employees were attempting to isolate a leak on a condensate line between the NGL plant and the refinery. Three crude units were damaged and two reformers were destroyed. The fire was extinguished approximately nine hours after the initial explosion. Five people were killed and 50 others were injured. Initial investigation into the loss indicates a lack of inspection and maintenance of the condensate line.

June 25, 2000

Mina Al-Ahmadi, Kuwait

\$412,000,000 (2000 dollars)

From the Marsh and McLennan Report, *The 100 Largest Losses 1972-2001*, 20th Edition: February 2003, a publication of Marsh's Risk Consulting Practice

Introduction

- Routine straight beam ultrasonic inspection (UT) is by far the most common method (and often the only) of inspection independent of the expected damage mechanism assessment
- Often a detailed analysis of the UT data is not done to determine the quality of the data, adequate coverage of inspection points, etc.

Introduction

- Most refining, mid-stream, and chemicals pressurized equipment was designed and built for an operating basis different than current operation
- Plants continuously “tweak” the process to raise throughput or process poorer quality (lower cost) feedstocks (crudes or intermediates)
- Long term effect is cumulative so that minor changes may cause a significant increase in damage rates

Piping Programs

- CMLs must be placed in the correct locations, and used with appropriate NDE
 - Guidance/Input from corrosion engineers for placement decisions
 - RBI not used to quantify risk reduction/investment payback
 - Use statistics as applicable to determine optimal sampling
- An overabundance of CMLs results in non-value-added activities
- Integrate and define the value of corrosion reviews, Fitness for Service evaluations, RBI and statistical analyses in the inspection and planning process for optimal effectiveness

Piping Programs

- Considerations for Inspection Database programs (IDBMS)
 - How much change has occurred between measurements?
 - How accurate are the measured corrosion rates?
 - How do we use retirement dates (based on $\frac{1}{2}$ life)?
 - What the basis for retirement limit (nominal + CA)?
 - How was the program initially set-up?
 - How were circuits defined?
 - Was corrosion and expected damage mechanisms used for defining inspection scope, type and location?
- Plants are aging
 - Failure rates will increase without effective change

Piping Programs

- Requires a shift from original basis to consider why, where, when, how to inspect
- RBI Principles
 - Qualitatively grade the effectiveness of NDE
 - Probability of failure involves uncertainty
 - Consequence
- FFS Principles
 - Limiting flaw size
 - Accuracy of NDE
- Proactive approaches
 - Corrosion systemization and circuitization
 - Operating Envelopes (MOEs)
 - Management of Change (MOCs)

Available Tools

- Codes & Standards permit use of and provide minimum guidelines for
 - RBI
 - FFS
 - Jurisdictional
- Supporting documents
 - 580
 - 581
 - API/ASME ISIJC

Available Tools

- Codes and Standards
 - Latest editions of API 570, 574, 579, 580, 581
- RBI
 - Damage mechanism assignment is a critical element
- FFS
 - Engineering Analysis
 - Damage mechanism assignment is a critical element
- Corrosion and materials review
 - Systemization and circuitization
 - RBI damage mechanism assignment
 - MOE

Available Tools

- Materials/corrosion review with assignment of active damage mechanisms
 - Critical to the success of any equipment reliability program
 - Critical to success of any RBI process
 - Required by codes, standards and regulators
 - Should include special emphasis mechanisms (e.g., Stress Corrosion Cracking, Creep, Wet H₂S)

When to Consider an MOE

- Complimentary Approach: Material Operating Envelopes (MOE)
- Proactively or in response to an incident
- In conjunction with a critical Fitness-For-Service assessment
- Next step after doing RBI

Materials Operating Envelopes

- Identify key parameters and ranges
- Traditional piping inspection programs rely on future operating conditions replicating past operating conditions
- RBI typically focused more on inspection activities than on controlling operations and identifying monitoring activities
- Knowledge and control of operating envelope helps provide an improved chance for reliability and safety, due to increasing knowledge of actual operating parameters
- An MOE defines the envelope for predictable degradation versus specific operating parameters

Defining Limits

- Similar to KPRP's
- Contain some parameters that may not be controllable, but must be measured and trended
- Defines limits operation (feed contaminant content, pH, flow rate, temperatures, chemical or water injection rates) and acceptable levels of corrosive constituents
- Control of operating parameters to minimize corrosion/degradation
- Modeling required with sampling/inspection to verify assumptions about constituents or conditions not being present
- Limits exceeded and degradation accelerated may trigger inspection, RBI, FFS updates or other actions

Inspection Benefits of MOE

- Identify need for more UT coverage in some areas and less in other areas
- Identify improper inspection procedures being applied
- Identify equipment taken out of service with blinding points that create process deadlegs
- Identify equipment being cycled in/out of service creating CUI concerns

Piping Circuitization

- Use an experienced corrosion/materials engineer to define systems in each unit
- Define corrosion circuits within each system based on materials of construction, operating conditions and active damage mechanisms
- Circuit identification and naming convention is used for both API RBI and IDBMS programs to provide linking and sharing inspection data
- Analysis is performed on circuit inspection results to determine circuit corrosion rate and measured thickness/dates for circuit components
- Circuit corrosion rates are used in API RBI to calculate circuit risk
- Determine the circuit and component next inspection date and inspection effectiveness, including detailed inspection plan
- Review or Placement of CML/TML recommended by corrosion/materials engineer
- CML/TML installed and documented on piping Isometric drawings




Example 1

HDS Unit



System Key – HDS

-  1) HDS Feed
-  2) 1st Stage Reactor & Effluent
-  3) 2nd Stage Reactor & Effluent
-  4) Recycle Hydrogen & Effluent
-  5) Make-up Hydrogen
-  6) Naphtha Stripper Feed
-  7) Naphtha Stripper Overhead & Reflux
-  8) Naphtha Stripper Bottoms & Reboiler
-  9) CCR Feed
-  10) #1 Reactor Feed Effluent
-  11) #2 Reactor Feed Effluent
-  12) #3 Reactor Feed Effluent
-  13) #4 Reactor Feed Effluent
-  14) Reformer Recycle Hydrogen
-  15) Net Gas Compression
-  16) Net Gas Chloride Treaters
-  17) LPG Recovery Propane Compression & Chiller
-  18) Debutanizer Feed
-  19) Debutanizer Overhead & Reflux
-  20) Debutanizer Bottoms & Reboiler
-  21) Benzene Overhead & Reflux
-  22) Benzene Aromatic Product
-  23) Benzene Bottoms & Reboiler



NOTES
 PROCESS CONDITIONS SHOWN CORRESPOND TO FEED STOCK 1 CASE.
 PROCESS CONDITIONS REVISED BASED ON THE HEAT AND MATERIAL
 BALANCE (REV 1 DATED 04 NOV '94) FURNISHED BY FP.

- LEGEND**
- ◇ STREAM NUMBER
 - PRESSURE, PSIG
 - TEMPERATURE, °F
 - ▭ FLOW, MASC/D
 - ▭ FLOW, BPSD
 - ▭ FLOW, GPM
 - ▭ FLOW, LBS/HR
 - ▭ DUTY, MMBTU/HR

STREAM NO.	FEED STOCK 1 START OF RUN																
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
DESCRIPTION	NAPHTHA FROM STORAGE	NAPHTHA FROM GPP	COMBINED FEED	H ₂ FROM REFORMER	REACTOR 1 INLET	H ₂ MAKE-UP TO REACTOR 1	H ₂ RECYCLE TO REACTOR 1	X-16001 INLET	H ₂ RECYCLE TO RA-16002	X-16002/3/4/5 INLET	RA-16002 INLET	RA-16002 QUENCH	H ₂ PURGE	COMBINED COMPRESSOR INLET	STRIPPER FEED	RA-16002 H ₂ QUENCH	
LES/HR	30,049	132,873	162,922	3,878	164,585	2,033	1,844	164,585	0,254	11,267	175,852	207,563	10,858	352	35,318	166,246	14,859
MASC/D	2,800	12,200	15,000	0.53	4.72	3.82	14.73	18.45	—	23.58	17.38	0.18	0.18	58.21	—	23.54	—
BPSD	101	101	83	3.8	83.4	3.8	3.8	75.7	5.7	5.3	42.8	25	5.7	5.7	5.7	87.2	5.7
MW	101	101	83	3.8	83.4	3.8	3.8	75.7	5.7	5.3	42.8	25	5.7	5.7	5.7	87.2	5.7
API	60.8	58.2	58.7	—	—	—	—	—	—	—	—	—	—	—	—	—	—


STREAM NO.	FEED STOCK 1 END OF RUN																
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
DESCRIPTION	NAPHTHA FROM STORAGE	NAPHTHA FROM GPP	COMBINED FEED	H ₂ FROM REFORMER	REACTOR 1 INLET	H ₂ MAKE-UP TO REACTOR 1	H ₂ RECYCLE TO REACTOR 1	X-16001 INLET	H ₂ RECYCLE TO RA-16002	X-16002/3/4/5 INLET	RA-16002 INLET	RA-16002 QUENCH	H ₂ PURGE	COMBINED COMPRESSOR INLET	STRIPPER FEED	RA-16002 H ₂ QUENCH	
LES/HR	30,049	132,873	162,922	3,878	164,585	2,033	1,844	164,585	0,254	11,267	175,852	207,563	10,858	352	35,318	166,246	14,859
MASC/D	2,800	12,200	15,000	0.53	4.72	3.82	14.73	18.45	—	23.58	17.38	0.18	0.18	58.21	—	23.54	—
BPSD	101	101	83	3.8	83.4	3.8	3.8	75.7	5.7	5.3	42.8	25	5.7	5.7	5.7	87.2	5.7
MW	101	101	83	3.8	83.4	3.8	3.8	75.7	5.7	5.3	42.8	25	5.7	5.7	5.7	87.2	5.7
API	60.8	58.2	58.7	—	—	—	—	—	—	—	—	—	—	—	—	—	—

RA-16001
 FIRST STAGE LIQUID PHASE REACTOR
 SIZE 6'-0" ID. x 82'-9" T-T
 DESIGN PRESS 842 PSIG
 DESIGN TEMP 540°F

X-16012
 START-UP HEATER
 DUTY 17,511 MM BTU/HR
 SURFACE AREA 1,250 SQ. FT.
 SHELL SIDE DP 675 PSIG
 DT 750°F
 SHELL SIDE UPSET DP 850 PSIG
 UPSET DT 450°F
 TUBE SIDE DP 850 PSIG
 DT 520°F

X-16001
 1ST STAGE REACTOR FEED VS.
 2ND STAGE REACTOR EFFLUENT
 DUTY 2,9165 MM BTU/HR
 SURFACE AREA 4,100 SQ. FT.
 SHELL SIDE DP 675 PSIG
 DT 800°F
 TUBE SIDE DP 871 PSIG
 DT 520°F

X-16002/3/4/5
 SECOND STAGE REACTOR FEED VS. EFFLUENT
 DUTY 21,53 MMBTU/HR
 SURFACE AREA 11,480 SQ. FT.
 SHELL SIDE DP 715 PSIG
 DT 815°F (2) / 865°F (3) / 715°F (4 & 5)
 TUBE SIDE DP 785 PSIG
 DT 520°F (2) / 560°F (3) / 560°F (4 & 5)



NOTES:
 1. INSTRUMENT NUMBERS SHOWN IN PARENTHESES ARE NUMBERS TO BE COVERED BY FIELD
 2. FOR SAMPLE DETAILS, SEE DETAIL "A" DWG. LC-15-06-AUX-01-D.

— CIRC-2
 — CIRC-3

- HDS
- 10-00-01
- 10-01-01
- 10-01-02
- 10-01-03
- 10-01-03-8
- 10-02-01
- 10-02-02
- 10-02-03
- 10-03-01
- 10-03-02
- 10-03-03
- 10-03-04
- 10-03-05
- 10-03-06
- 10-04-01
- 10-04-02
- 10-04-02A
- 10-04-05
- 10-04-05A
- 10-04-05B
- 10-04-06
- 10-05-02
- 10-05-02A
- 10-05-03
- 10-05-03A
- 10-06-01
- 10-06-02
- 10-07-01
- 10-07-03
- 10-07-04
- 10-07-05
- 10-08-01
- 10-08-02
- 10-08-03
- 10-08-04
- 10-08-05
- 10-08-06
- D-16001
- D-16002
- D-16003
- D-16004
- D-16005

Thinning / Equipment Linings

What-If

Component

Thinning Thinning Supplement Equipment Lining

Input Data

Online Monitoring

Injection Point

Injection Point Inspection

Deadleg

Deadleg Inspection

Thinning Type

BM Gov Thinning Mech

CM Gov Thinning Mech

Thinning Damage Mechanism

Other Thinning Damage

Damage Drivers

BM Spec

BM Grade

Design Temperature (°F)

Design Pressure (psig)

Component Start Date (yyyy-mm-dd)

Furnished Thickness (in)

Inspection Date (yyyy-mm-dd)

Measured Thickness (in)

Operating Temperature (°F)

Operating Pressure (psig)

Base Material

Corrosion Rate

Estimated Rate (mpy)

Measured Rate (mpy)

Gov Thinning Corrosion Rate (mpy)

Clad Material

Corrosion Rate

Estimated Rate (mpy)

Measured Rate (mpy)


Gov Thinning Corrosion Rate (mpy)

Calculated Results

Highest Effective Insp <input type="text" value="E"/>	Total DF <input type="text" value="3.4456"/>	Risk Category <input type="text" value="MEDIUM-HIGH"/>
No Highest Effective Insp <input type="text" value="0.000"/>	POF <input type="text" value="1.05435E-04"/>	Maximum Risk <input type="text" value="1.483392472938"/>
Age (yrs) <input type="text" value="11.3292265571526"/>	COF (ft*) <input type="text" value="1.40692E+04"/>	Financial Risk (\$/yr) <input type="text" value="3661.234758665"/>
DF <input type="text" value="3.0000"/>	Risk Matrix <input type="text" value="2E"/>	
Likelihood Category <input type="text" value="2"/>		

Circuit Summary


- System Summary – Feed line carrying Virgin Naphtha, Cracked Naphtha and Heavy Naphtha through preheat to first stage reactor
- Circuit Summary – Circuit 3 includes piping from first stage reactor feed (channel) to first stage reactor
- Material of Construction – Carbon Steel
- Estimated Corrosion Rate – 2 mpy
- Corrosion Type – General
- Primary Damage Mechanism – None
- Specific Location Concerns – None
- Deadlegs – 2 potential, created bypass line and closed valve during operation



NOTES
 PROCESS CONDITIONS SHOWN CORRESPOND TO FEED STOCK 1 CASE.
 PROCESS CONDITIONS REVISED BASED ON THE HEAT AND MATERIAL
 BALANCE (REV 1 DATED 04 NOV '94) FURNISHED BY FP.


STREAM NO.	FEED STOCK 1 START OF RUN																
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
DESCRIPTION	NAPHTHA FROM STORAGE	NAPHTHA FROM GPP	COMBINED FEED	H ₂ FROM REFORMER	REACTOR 1 INLET	H ₂ MAKE-UP TO REACTOR 1	H ₂ REACTOR 1 INLET	X-16001 RECYCLE	H ₂ RECYCLE TO RA-16002	X-16002/3/4/5 INLET	RA-16002 OUTLET	RA-16002 H ₂ PURGE	STRIPPER FEED	RA-16002 H ₂ PURGE	STRIPPER FEED	RA-16002 H ₂ PURGE	STRIPPER FEED
LES/HR	30,049	132,873	162,922	3,878	184,585	2,033	1,844	184,585	0,254	11,267	175,882	207,583	18,858	382	38,318	188,248	14,858
MASC/D	2,800	12,200	15,000	0.53	4.7	3.82	—	14.73	18.45	—	23.58	17.38	0.18	—	38.21	—	23.84
BPSD	101	101	83	3.8	83.4	3.8	3.8	78.7	5.7	5.3	42.8	25	5.7	5.7	5.7	87.2	5.7
MW	101	101	83	3.8	83.4	3.8	3.8	78.7	5.7	5.3	42.8	25	5.7	5.7	5.7	87.2	5.7
API	60.8	58.2	58.7	—	—	—	—	—	—	—	—	—	—	—	—	—	—

STREAM NO.	FEED STOCK 1 END OF RUN																
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
DESCRIPTION	NAPHTHA FROM STORAGE	NAPHTHA FROM GPP	COMBINED FEED	H ₂ FROM REFORMER	REACTOR 1 INLET	H ₂ MAKE-UP TO REACTOR 1	H ₂ REACTOR 1 INLET	X-16001 RECYCLE	H ₂ RECYCLE TO RA-16002	X-16002/3/4/5 INLET	RA-16002 OUTLET	RA-16002 H ₂ PURGE	STRIPPER FEED	RA-16002 H ₂ PURGE	STRIPPER FEED	RA-16002 H ₂ PURGE	STRIPPER FEED
LES/HR	30,049	132,873	162,922	3,878	184,585	2,033	1,844	184,585	0,254	11,267	175,882	188,507	18,727	382	38,091	188,248	14,727
MASC/D	2,800	12,200	15,000	0.53	4.72	3.82	—	14.73	18.45	—	23.58	17.38	0.18	—	38.21	—	23.84
BPSD	101	101	83	3.8	83.4	3.8	3.8	78.7	5.7	5.3	42.8	25	5.7	5.7	5.7	87.2	5.7
MW	101	101	83	3.8	83.4	3.8	3.8	78.7	5.7	5.3	42.8	25	5.7	5.7	5.7	87.2	5.7
API	60.8	58.2	58.7	—	—	—	—	—	—	—	—	—	—	—	—	—	—



-CIRC 1

RA-16002
 SECOND STAGE REACTOR
 SIZE 9'-6" ID. x 30'-3" T-T
 DESIGN PRESS 750 PSIG
 DESIGN TEMP 750°F



- CIRC1
 - CIRC2

LEGEND

OUT OF SERVICE

NOTES

1. ALL OR A PORTION OF THIS LINE WAS PART OF A PRELIMINARY AND MECHANICAL STUDY BY DRESSER/PNEU. CHANGES OR ADDITIONS TO THIS Piping DURING OR AFTER CONSTRUCTION ARE NOT PERMITTED WITHOUT PRIOR WRITTEN CONSENT FROM ARI LUMAS GLOBAL AND CONOCO ENGINEERING.

Thinning / Equipment Linings

What-If

Component

Thinning Equipment Lining

Input Data

Online Monitoring	<input type="text" value="N-None"/>
Injection Point	<input type="text" value="No"/>
Injection Point Inspection	<input type="text" value="No"/>
Deadleg	<input type="text" value="No"/>
Deadleg Inspection	<input type="text" value="No"/>
Thinning Type	<input type="text" value="General"/>
BM Gov Thinning Mech	<input type="text" value="Thinning supplement not specified"/>
CM Gov Thinning Mech	<input type="text" value="Thinning supplement not specified"/>
Thinning Damage Mechanism	<input type="text" value="H2SM2 Corrosion"/>
Other Thinning Damage	<input type="text" value=""/>

Damage Drivers

BM Spec	<input type="text" value="A335"/>
BM Grade	<input type="text" value="P9"/>
Design Temperature (°F)	<input type="text" value="1100.0"/>
Design Pressure (psig)	<input type="text" value="80.0"/>
Component Start Date (yyyy-mm-dd)	<input type="text" value="1995-01-01"/>
Furnished Thickness (in)	<input type="text" value="0.3750000"/>
Inspection Date (yyyy-mm-dd)	<input type="text" value=""/>
Measured Thickness (in)	<input type="text" value=""/>
Operating Temperature (°F)	<input type="text" value="530.0"/>
Operating Pressure (psig)	<input type="text" value="660.0"/>

Base Material

Corrosion Rate	<input type="text" value="Estimated"/>
Estimated Rate (mpy)	<input type="text" value="4"/>
Measured Rate (mpy)	<input type="text" value="0.000"/>
Gov Thinning Corrosion Rate (mpy)	<input type="text" value="0.0"/>

Clad Material

Corrosion Rate	<input type="text" value="Estimated"/>
Estimated Rate (mpy)	<input type="text" value="0.000"/>
Measured Rate (mpy)	<input type="text" value="0.000"/>
Gov Thinning Corrosion Rate (mpy)	<input type="text" value="0.0"/>

Calculated Results

Highest Effective Insp	<input type="text" value="E"/>	Total DF	<input type="text" value="33.200"/>	Risk Category	<input type="text" value="HIGH"/>
No Highest Effective Insp	<input type="text" value="0.000"/>	POF	<input type="text" value="1.01592E-03"/>	Maximum Risk	<input type="text" value="10.89243709009"/>
Age (yrs)	<input type="text" value="11.3292265571526"/>	COF (ft²)	<input type="text" value="1.07217E+04"/>	Financial Risk (\$/Yr)	<input type="text" value="2.16435E+04"/>
DF	<input type="text" value="0.000"/>	Risk Matrix	<input type="text" value="3E"/>		
Likelihood Category	<input type="text" value="1"/>				

Save

Help


Delete

Calculate

Comments

Circuit Summary

- System Summary – Second Stage Reactor & Effluent
- Circuit Summary – Circuit 1 piping from the Second Stage Reactor Fired Heater to Second Stage Reactor
- Material of Construction – 9 Cr - 1/2 Mo
- Estimated Corrosion Rate – 4 mpy
- Corrosion Type – General
- Primary Damage Mechanism – H₂H₂S, HTHA (none)
- Specific Location Concerns – Straight run piping with potential high velocity conditions



NOTES
 PROCESS CONDITIONS SHOWN CORRESPOND TO FEED STOCK 1 CASE.
 PROCESS CONDITIONS REVISED BASED ON THE HEAT AND MATERIAL
 BALANCE (REV 1 DATED 04 NOV '94) FURNISHED BY FP.

- LEGEND**
- ◇ STREAM NUMBER
 - PRESSURE, PSIG
 - TEMPERATURE, °F
 - ▬ FLOW, MASC/D
 - ▬ FLOW, BPSD
 - ▬ FLOW, GPM
 - ▬ FLOW, LBS/HR
 - ▬ DUTY, MMBTU/HR

STREAM NO.	FEED STOCK 1 START OF RUN																
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
DESCRIPTION	NAPHTHA FROM STORAGE	NAPHTHA FROM GPP	COMBINED FEED	H ₂ FROM REFORMER	REACTOR 1 INLET	H ₂ MAKE-UP TO REACTOR 1	H ₂ REACTOR 1 INLET	H ₂ RECYCLE TO RA-16002	H ₂ RECYCLE TO RA-16002	X-16002/3/4/5 INLET	RA-16002 INLET	RA-16002 QUENCH	H ₂ PURGE	COMBINED COMPRESSOR INLET	STRIPPER FEED	RA-16002 H ₂ QUENCH	RA-16002 H ₂ QUENCH
LES/HR	30,049	132,873	162,922	3,678	164,565	2,033	1,644	164,565	0,254	11,267	175,862	207,563	10,858	362	36,318	166,246	14,858
MASC/D	2,800	12,200	15,000	0.53	4.7	3.82	-	14.73	18.46	73.58	17.38	0.18	0.81	34.21	1,544	1,372	15.58
BPSD	101	101	83	3.8	83.4	3.8	3.8	75.7	5.7	5.3	42.8	25	5.7	5.7	87.2	5.7	5.7
MW	101	101	83	3.8	83.4	3.8	3.8	75.7	5.7	5.3	42.8	25	5.7	5.7	87.2	5.7	5.7
API	60.8	58.2	58.7	-	-	-	-	-	-	-	-	-	-	-	-	-	-

STREAM NO.	FEED STOCK 1 END OF RUN																
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
DESCRIPTION	NAPHTHA FROM STORAGE	NAPHTHA FROM GPP	COMBINED FEED	H ₂ FROM REFORMER	REACTOR 1 INLET	H ₂ MAKE-UP TO REACTOR 1	H ₂ REACTOR 1 INLET	H ₂ RECYCLE TO RA-16002	H ₂ RECYCLE TO RA-16002	X-16002/3/4/5 INLET	RA-16002 INLET	RA-16002 QUENCH	H ₂ PURGE	COMBINED COMPRESSOR INLET	STRIPPER FEED	RA-16002 H ₂ QUENCH	RA-16002 H ₂ QUENCH
LES/HR	30,049	132,873	162,922	3,678	164,565	2,033	1,644	164,565	0,254	11,267	175,862	207,563	10,858	362	36,318	166,246	14,858
MASC/D	2,800	12,200	15,000	0.53	4.7	3.82	-	14.73	18.46	73.58	17.38	0.18	0.81	34.21	1,544	1,372	15.58
BPSD	101	101	83	3.8	83.4	3.8	3.8	75.7	5.7	5.3	42.8	25	5.7	5.7	87.2	5.7	5.7
MW	101	101	83	3.8	83.4	3.8	3.8	75.7	5.7	5.3	42.8	25	5.7	5.7	87.2	5.7	5.7
API	60.8	58.2	58.7	-	-	-	-	-	-	-	-	-	-	-	-	-	-

ACTOR EFFLUENT AIR COOLER FANS

ACTOR EFFLUENT AIR COOLER MOTORS

WASH WATER PUMP

RATED HEAD | 1583 FT
 NORMAL CAPACITY | 33 GPM @ 100F

WASH WATER PUMP MOTORS


WASH WATER BREAK TANK

SIZE | 3'-0" I.D. x 13'-0" T-T
 DESIGN PRESS | 148 PSIG
 DESIGN TEMP | 150F

REACTOR EFFLUENT

DUTY | 6.
 SURFACE AREA | 44
 SHELL SIDE DP | 64
 DT | 44
 TUBE SIDE DP | 44
 DT | 11

- CIRC 4
- CIRC 5
- CIRC 6



Circuit Summary

- System Summary – Second Stage Reactor & Effluent
- Circuit Summary – Circuit 5 Piping from the Reactor Effluent Air Coolers to the Shell Side of Reactor Effluent Trim Cooler
- Estimated Corrosion Rate – 7 mpy
- Corrosion Type – Local
- Primary Damage Mechanism – Ammonium Bisulfide/Chlorides
- Specific Location Concerns – Elbows, high velocity areas (>20 ft/sec)

Piping Risk Analysis Summary

- HDS Unit with 8 PFD, 67 P&ID's and 1,670 lines in the line list provided for the study:
 - Develop corrosion systems and circuits with common damage mechanisms and expected corrosion rates for the main hydrocarbon containing lines and branch connections (utilities services, drain lines, flare lines were excluded).
 - Integrate the new defined corrosion circuits with existing RBI file (naming conventions, re-grouping at the circuit level).
 - Estimate the corrosion rate on a circuit basis and add to the RBI file.
 - Add all necessary mechanical and operating data for each piping circuit in the existing RBI files and recalculate the risk/inspection plans for this Unit.
 - Develop color coded piping System and Circuit drawings utilizing the PFD's and P&ID's.

HDS Summary

- 23 Systems
- 146 Circuits
- 27 circuits (~18%) which potentially problems due to:
 - Material of construction at the current operating conditions
 - Piping design (location of check valves, specification break, etc.)
- Potential problems due to corrosion in H₂S, Chlorides, Ammonia bisulfide, Ammonia Chlorides environments; High Temperature service (creep); Corrosion Under Insulation (CUI)



Example 2


Gas Plant




System Key – Gas Plant

Process Stream	Identifier	Color Code
RAW FEED	FD	Yellow
STABILIZED FEED CONDENSATE	STAB	Yellow with vertical lines
COMPRESSION	COMP	Light Green
DEHYDRATION 1	DEHY1	Orange
DEHYDRATION 2	DEHY2	Orange with vertical lines
CRYOGENICS TRAIN A	CRYOA	Blue
CRYOGENICS TRAIN B	CRYOB	Blue with vertical lines
DEMETHANIZER BOTTOMS TRAIN A	DMBA	Pink with vertical lines
DEMETHANIZER OVERHEADS TRAIN A	DMOA	Pink
DEMETHANIZER BOTTOMS TRAIN B	DMBB	Pink with vertical lines
DEMETHANIZER OVERHEADS TRAIN B	DMOB	Pink with vertical lines
REGENERATION	REGEN	Magenta
REFRIGERATION	RFG	Brown
LUBE OIL	LBOIL	Grey
FUEL GAS	FLG	Light Green
HEAT MEDIUM	HTOIL	Cyan
FLARE	FLR	Orange
DRAIN	DRN	Green



Feed System



Feed System



Feed System



Thinning / Equipment Linings

What-If Component From V-1011-Top to SC-2020A GS-1030, 1040, 1050

Thinning Thinning Supplement Equipment Lining

Input Data

Online Monitoring

Injection Point

Injection Point Inspection

Deadleg

Deadleg Inspection

Thinning Type

BM Gov Thinning Mech

CM Gov Thinning Mech

Thinning Damage Mechanism

Other Thinning Damage

Damage Drivers

BM Spec

BM Grade

Design Temperature (°F)

Design Pressure (psig)

Component Start Date (yyyy-mm-dd)

Furnished Thickness (in)

Inspection Date (yyyy-mm-dd)

Measured Thickness (in)

Operating Temperature (°F)

Operating Pressure (psig)

Base Material

Corrosion Rate

Estimated Rate (mpy)

Measured Rate (mpy)

Gov Thinning Corrosion Rate (mpy)

Clad Material

Corrosion Rate

Estimated Rate (mpy)

Measured Rate (mpy)

Gov Thinning Corrosion Rate (mpy)

Calculated Results


Highest Effective Insp	<input type="text"/>	Total DF	<input type="text"/>	Risk Category	<input type="text"/>
No Highest Effective Insp	<input type="text"/>	POF	<input type="text"/>	Maximum Risk	<input type="text"/>
Age (yrs)	<input type="text"/>	COF (ft²)	<input type="text"/>	Financial Risk (\$/yr)	<input type="text"/>
DF	<input type="text"/>	Risk Matrix	<input type="text"/>		
Likelihood Category	<input type="text"/>				

- DRN-75
- DRN-76
- DRN-77
- DRN-78
- DRN-79
- DRN-80
- DRN-81
- DRN-82
- DRN-83
- DRN-84
- DRN-V5411-TRM
- DRN-V5416-TRM
- FD-01
- FD-02
- FD-03
- FD-04
- FD-05
- FD-06
 - FD-06-3
- FD-07
- FD-08
- FD-09
- FD-10
- FD-11
- FD-12
- FD-13
- FD-14
- FD-15
- FD-F2201-1-TRM
- FD-F2201-2-TRM
- FD-F2201-3-TRM
- FD-F2201-4-TRM
- FD-F2301-1-TRM
- FD-F2301-1A-TRM
- FD-F2301-1B-TRM
- FD-F2301-2-TRM
- FD-F2301-2A-TRM
- FD-F2301-2B-TRM
- FD-H1135A-TRM
- FD-V1011-TRM
- FD-V1012-TRM
- FD-V1112-TRM


Circuit Summary

- System Summary – Feed line from offshore platforms to Dehydration system
- Circuit Summary – Circuit 6 includes piping from the Stabilizer Feed Drum top to the Stabilizer Overhead Compressor Skid
- Material of Construction – Carbon Steel
- Estimated Corrosion Rate (internal) – 3 mpy
- Corrosion Type – General
- External Corrosion Rate – 2.9 mpy
- Primary Damage Mechanism – CUI
- Specific Location Concerns
 - Internal corrosion - low points and deadlegs, areas where water collects
 - Damaged insulation or weatherproofing
- Deadlegs – 3 potential

Cryogenic System



UKT017



- Plant
- COMP-01
- COMP-02
- COMP-03
- COMP-04
- COMP-05
- COMP-06
- CRYOA-01
- CRYOA-01-1
- CRYOA-02
- CRYOB-01
- CRYOB-02
- DEHY1-01
- DEHY1-02A
- DEHY1-02B
- DEHY1-03A
- DEHY1-03B
- DEHY1-04A
- DEHY1-04B
- DEHY1-05A
- DEHY1-05B
- DEHY1-06A
- DEHY1-06B
- DEHY1-07A
- DEHY1-07B
- DEHY1-08A
- DEHY1-08B
- DEHY1-09A
- DEHY1-09B
- DEHY1-10
- DEHY1-11
- DEHY1-12
- DEHY1-13
- DEHY1-14
- DEHY1-V3041-T
- DEHY1-V3141-T
- DEHY2-01
- DEHY2-02
- DEHY2-03
- DEHY2-04
- DEHY2-05A
- DEHY2-05B
- DEHY2-06
- DEHY2-07
- DEHY2-08
- DEHY2-09
- DEHY2-10
- DEHY2-11

Thinning / Equipment Linings

What-If Component From to to/from

Thinning Thinning Supplement Equipment Lining

Input Data

Online Monitoring

Injection Point

Injection Point Inspection

Deadleg

Deadleg Inspection

Thinning Type

BM Gov Thinning Mech

CM Gov Thinning Mech

Thinning Damage Mechanism

Other Thinning Damage

Damage Drivers

BM Spec

BM Grade

Design Temperature (°F)

Design Pressure (psig)

Component Start Date (yyyy-mm-dd)

Furnished Thickness (in)

Inspection Date (yyyy-mm-dd)

Measured Thickness (in)

Operating Temperature (°F)

Operating Pressure (psig)

Base Material

Corrosion Rate

Estimated Rate (mpy)

Measured Rate (mpy)

Gov Thinning Corrosion Rate (mpy)

Clad Material

Corrosion Rate

Estimated Rate (mpy)

Measured Rate (mpy)

Gov Thinning Corrosion Rate (mpy)

Calculated Results

Highest Effective Insp <input type="text" value="E"/>	Total DF <input type="text" value="519.1666666666"/>	Risk Category <input type="text" value="HIGH"/>
No Highest Effective Insp <input type="text" value="0.000"/>	POF <input type="text" value="0.01589"/>	Maximum Risk <input type="text" value="274.8460465559"/>
Age (yrs) <input type="text" value="9.43737166324435"/>	COF (ft*) <input type="text" value="1.73006E+04"/>	Financial Risk (\$/yr) <input type="text" value="2.95456E+05"/>
DF <input type="text" value="519.16666666667"/>	Risk Matrix <input type="text" value="4E"/>	
Likelihood Category <input type="text" value="4"/>		

Circuit Summary

- System Summary – Piping from the Expander to Demethanizer Column and from the Cold Gas/Gas Exchangers; MeOH injection point in this system
- Circuit Summary – Circuit 1 includes piping from the Expander to the Demethanizer and to/from the Cold Side Reboiler
- Material of Construction – Stainless Steel
- Estimated Corrosion Rate (internal) – 0 mpy
- Corrosion Type – General
- External Corrosion Susceptibility – None
- Primary Damage Mechanism – CUI Austenitic Stainless Steels
- Specific Location Concerns – Possible CUI concerns at interface of insulated equipment and un-insulated protrusions
- 7 potential Deadlegs; 1 potential injection/mix point

Gas Plant Summary

- 18 Systems
- 344 Circuits
- 28 circuits (~8%) with potential internal corrosion in aqueous conditions
- Potential problems due to aqueous corrosion due to low levels of H₂S and water
- Corrosion Under Insulation (CUI) in marine environment and in Gulf coastline (hurricane) affects potentially 75% of piping

Link to Inspection Database

- Establish basis for linking and sharing data between API RBI and IDBMS program
 - Unit identifier
 - Equipment/Pipe identifier
 - Component/Pipe identifier
- TML Number identifier
- TML Location/Type (shell, pipe, elbow, tee, nozzle, vertical, horizontal)

Inspection Interval

- Half Life inspection due date – Inspection database program based on wall loss from previous inspection date
- RBI due date – Risk based date for inspection based on Risk Target
- Jurisdiction – Inspection based on fixed interval from last inspection

TML/CML INSPECTION PROGRAM

Consequence Category

INSPECTION PLANNING

RBI ASSESSMENT

INSPECTION RECOMMENDATIONS

RBI ASSESSMENT DATA

PLAN RBI INSPECTION ACTIVITIES

DOCUMENT INSPECTION & RESULTS

Probability Category

		D	E
4	2	2	1
3	2	3	0
2	1	13	4
1	1	4	7
	4	5	8
Risk Rank	Low	Medium	Medium High

Bold Outline Boxes indicate Target Risk



Risk Matrix Report

Current Risk | Future Risk With No Inspection | Future Risk With Inspection

Current Risk

Unit: HDS

		Consequence Category						
		A	B	C	D	E		
Probability Category	5	1	0	3	0	1	5	
	4	1	2	2	0	16	21	
	3	0	0	0	0	0	0	
	2	3	1	2	1	2	9	
	1	37	18	7	20	23	105	
		42	21	14	21	42		

Risk Rank Totals		140	
High	17	12.14	
MediumHigh	31	22.14	
Medium	33	23.57	
Low	59	42.14	

Sun Dec 07 18:20:50 CST 2008

OK Export Print

Components with Risk Matrix 4E

- W-16001|W-16001-TOP
- X-16007|X-16007-S
- X-16008|X-16008-S
- X-16009|X-16009-S
- X-16010|X-16010-S
- D-16002|D-16002
- D-16003|D-16003
- D-16005|D-16005
- D-16008|D-16008
- D-16009|D-16009
- D-16012|D-16012
- D-16013|D-16013
- H-16001-CON|H-16001-C
- H-16001-RAD|H-16001-R
- 10-03-03|10-03-03-14
- 10-03-05|10-03-05-14

Ok

- localhost
- Corporation
- Refinery
- HDS
 - 10-00-01
 - 10-01-01
 - 10-01-02
 - 10-01-03
 - 10-02-01
 - 10-02-02
 - 10-02-03
 - 10-03-01
 - 10-03-02
 - 10-03-03
 - 10-03-04
 - 10-03-05
 - 10-03-05-14
 - 10-03-05-8
 - 10-03-06
 - 10-04-01
 - 10-04-02
 - 10-04-02A
 - 10-04-05
 - 10-04-05A
 - 10-04-05B
 - 10-04-06
 - 10-05-02
 - 10-05-02A
 - 10-05-03
 - 10-05-03A
 - 10-06-01
 - 10-06-02
 - 10-07-01
 - 10-07-03
 - 10-07-04
 - 10-07-05
 - 10-08-01
 - 10-08-02
 - 10-08-03
 - 10-08-04
 - 10-08-05
 - 10-08-06
 - D-16001
 - D-16002
 - D-16003
 - D-16004
 - D-16005
 - D-16006

API RBI Analysis

Thinning / Equipment Linings

What-If Component

Thinning

Input Data

Online Monitoring

Injection Point

Injection Point Inspection

Deadleg

Deadleg Inspection

Thinning Type

BM Gov Thinning Mech

CM Gov Thinning Mech

Thinning Damage Mechanism

Other Thinning Damage

Damage Drivers

BM Spec

BM Grade

Design Temperature (°F)

Design Pressure (psig)

Component Start Date (yyyy-mm-dd)

Furnished Thickness (in)

Inspection Date (yyyy-mm-dd)

Measured Thickness (in)

Operating Temperature (°F)

Operating Pressure (psig)

Base Material

Corrosion Rate

Estimated Rate (mpy)

Measured Rate (mpy)

Gov Thinning Corrosion Rate (mpy)

Clad Material

Corrosion Rate

Estimated Rate (mpy)

Measured Rate (mpy)

Gov Thinning Corrosion Rate (mpy)

Calculated Results

Highest Effective Insp

No Highest Effective Insp

Age (yrs)

DF

Likelihood Category

Total DF

POF

COF (ft²)

Risk Matrix

Risk Category

Maximum Risk

Financial Risk (\$/yr)

Save Help Delete Calculate Comments

Measured corrosion rates and measured thickness by circuit.

API RBI Inspection Planning

Inspection Planning

Inspection Plan Option **PLAN**

Component 10-03-05-14

Inspection recommendations and due date.

General

Input Inspection Plan parameters

Inspection Plan Date (yyyy-mm-dd) 2016-05-01

Inspection Plan Basis AREA

Area Risk Target (ft²/yr) 35

Financial Risk Target (\$/year) 1000

Max Inspection Interval (yrs) 25

DF Target 5000

Calculated Inspection Plan

Plan Method RISK

	Category	Number	Inspection Date
Thinning	A	1	2006-05-01
Cracking	E	0	2006-05-01
External Damage	A	1	2006-05-01
HTHA	E	0	2006-05-01

Calculated Risk Results

	RBI Date		Target Date Without Inspection		Plan Date Without Inspection		Plan Date With Inspection	
Date (yyyy-mm-dd)	2006-05-01		2006-05-01		2016-05-01		2016-05-01	
Years from RBI Date	0.0		0.0		10.001		10.001	
Thinning Risk/DF	530.141	622.574	530.141	622.574	786.039	923.09	119.875	140.775
Cracking Risk/DF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
External Damage Risk/DF	63.248	74.276	63.248	74.276	63.248	74.276	2.172	2.551
Brittle Fracture Risk/DF	2.278	2.675	2.278	2.675	2.278	2.675	2.278	2.675
Mechanical Fatigue Risk/DF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
HTHA Risk/DF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total Risk/DF	532.419	625.249	532.419	625.249	788.317	925.765	122.153	143.451
Total Risk Gradient	26.176		26.176		30.203		14.095	
Risk Matrix	4E		4E		4E		4E	
Risk Category	HIGH		HIGH		HIGH		HIGH	
Mod. Inspection Plan Date	2016-05-01							

Detailed inspection plans include scope, damage mechanism and recommended inspection effectiveness.

API RBI Inspection Planning

Inspection Planning

Inspection Plan Option **DATE**

Component 10-03-05-14

General

Input Inspection Plan parameters

Inspection Plan Basis **AREA**

Area Risk Target (ft²/yr) 35

Financial Risk Target (\$/year) 1000

Max Inspection Interval (yrs) 25

DF Target 5000

Calculated Inspection Plan

Plan Method **RISK**

	Category	Number	Inspection Date
Thinning	A	1	2006-05-01
Cracking	E	1	2006-05-01
External Damage	A	1	2006-05-01
HTHA	E	1	

Actual Planned Inspection dates

Calculated Risk Results

	RBI Date		Target Date Without Inspection		Target Date With Inspection	
Date (yyyy-mm-dd)	2006-05-01		2006-05-01		2007-12-08	
Years from RBI Date	0.0		0.0		1.605	
Thinning Risk/DF	530.141	622.574	530.141	622.574	32.722	38.427
Cracking Risk/DF	0.0	0.0	0.0	0.0	0.0	0.0
External Damage Risk/DF	63.248	74.276	63.248	74.276	2.172	2.551
Brittle Fracture Risk/DF	2.278	2.675	2.278	2.675	2.278	2.675
Mechanical Fatigue Risk/DF	0.0	0.0	0.0	0.0	0.0	0.0
HTHA Risk/DF	0.0	0.0	0.0	0.0	0.0	0.0
Total Risk/DF	532.419	625.249	532.419	625.249	35.0	41.102
Total Risk Gradient	26.176		26.176		10.068	
Risk Matrix	4E		4E		3E	
Risk Category	HIGH		HIGH		HIGH	
Plan Date (yyyy-mm-dd)	2016-05-01					

Risk Associated with Inspection

Save

Help

Delete

View Plots

Recommendations

Calculate


Inspection Report

- HDS
- 10-00-01
- 10-01-01
- 10-01-02
- 10-01-03
- 10-02-01
- 10-02-02
- 10-02-03
- 10-03-01
- 10-03-02
- 10-03-03
- 10-03-04
- 10-03-05
- 10-03-05-14
- 10-03-05-8
- 10-03-06
- 10-04-01
- 10-04-02
- 10-04-02A
- 10-04-05
- 10-04-05A
- 10-04-05B
- 10-04-06
- 10-05-02
- 10-05-02A
- 10-05-03
- 10-05-03A
- 10-06-01
- 10-06-02
- 10-07-01
- 10-07-03
- 10-07-04
- 10-07-05
- 10-08-01
- 10-08-02
- 10-08-03
- 10-08-04
- 10-08-05
- 10-08-06
- D-16001
- D-16002
- D-16003
- D-16004
- D-16005
- D-16006
- D-16007
- D-16008
- D-16009

View Plots

- Available Plots**
- Risk
 - Risk Pie
 - Risk Bar
 - Risk No Inspection**
 - Risk Pie No Inspection
 - Risk Bar No Inspection
 - DF
 - DF No Inspection

Ok




- HDS
- 10-00-01
- 10-01-01
- 10-01-02
- 10-01-03
- 10-02-01
- 10-02-02
- 10-02-03
- 10-03-01
- 10-03-02
- 10-03-03
- 10-03-04
- 10-03-05
- 10-03-05-14
- 10-03-05-8
- 10-03-06
- 10-04-01
- 10-04-02
- 10-04-02A
- 10-04-05
- 10-04-05A
- 10-04-05B
- 10-04-06
- 10-05-02
- 10-05-02A
- 10-05-03
- 10-05-03A
- 10-06-01
- 10-06-02
- 10-07-01
- 10-07-03
- 10-07-04
- 10-07-05
- 10-08-01
- 10-08-02
- 10-08-03
- 10-08-04
- 10-08-05
- 10-08-06
- D-16001
- D-16002
- D-16003
- D-16004
- D-16005
- D-16006
- D-16007
- D-16008
- D-16009

View Plots

- Available Plots**
- Risk
 - Risk Pie
 - Risk Bar
 - Risk No Inspection
 - Risk Pie No Inspection
 - Risk Bar No Inspection
 - DF
 - DF No Inspection

Ok



Inspection Results into API RBI

Inspection History

Flow Order No 2501 Component 10-03-05-14 System Specifier

History Form | History Table | Material | Damage Mechanisms

Inspection Date 2008-10-15

Thinning
Inspection Category A
Measured Thickness 0.45

Cracking
Amine Inspection Category
Carbonate Inspection Category
Caustic Inspection Category
Chloride Inspection Category
HIC SOHIC H2S Inspection Category
HIC SOHIC HF Inspection Category
HSC HF Inspection Category
PTA Inspection Category
SSC H2S Inspection Category
Other Inspection Category

External Damage
CS&LA Inspection Category A
CSA&LA Measured Thickness 0.45
CS&LA CUI Inspection Category
CS&LA CUI Measured Thickness
SS External SCC Inspection Category
SS CUI Inspection Category

HTHA
Inspection Category

Embrittlement
Sigma Phase

Comment


Save Help

1 of 1

Record actual inspection effectiveness and measured thickness to be used in Risk determination

Updated measured corrosion rate also entered in Thinning Module and Risk recalculated for next interval recommendation.

Risk After Inspection



Inspection Results

- Inspection results and findings should be compared to expectations of damage
 - Thinning rate and type (general or localized)
 - Cracking inspection findings – if cracking was found and severity, if found
- Were there any inspection findings that could impact the RBI Assessment?
- Are there any MOC considerations that could impact the Risk Assessment?
- Any new information or findings should be noted and returned to the RBI analysis Team


Piping TML/CML Analysis

- Piping systematized and circuitized based on corrosion circuits
- Pipe line numbers identified on isometric drawings and grouped by assigned systems and circuits
- RBI component name linked to IDBMS program
- Thickness data by circuit evaluated
- Analysis:
 - Average measured corrosion rate by circuit compared to estimated rates in RBI program
 - Statistically evaluated thickness data determine measurement confidence and variability


Piping TML/CML Analysis

- Data from IDBMS program grouped by RBI defined system and circuits
- Analysis of thickness measurement data by:
 - Equipment thickness data
 - + Remove fabrication type and specific flow conditions that might increase variability
 - Component thickness data
 - + Evaluate diameter (thickness) contribution to measurement variability
 - + Remove fabrication type and specific flow conditions that might increase variability
 - + Evaluate diameter (thickness) contribution to measurement variability


Piping TML/CML Analysis Example



Piping TML/CML Analysis Example



Piping TML/CML Analysis Example



Piping TML/CML Analysis

- High data variability can be an indication of higher than expected corrosion rates and/or localized corrosion
- Data from TML measurements show a wide range of wall loss over time
 - +/- 0.02 considered good data
 - +/- 0.08 average data
 - > +/- 0.10 considered poor quality data
- High TML data variation can mask indications of localized thinning

Piping Program Benefits

- Groups components (i.e., circuits) where active damage mechanisms and damage rates are similar
- Allows comparison of measured data and corrosion rates with historical or expected rates as well as localized behavior
- Provides information for defining appropriate coverage of CML/TML as well as other more appropriate inspection methods
- May identify undetected or localized corrosion issues that exist
- Calculates Risk and recommends inspection at circuit level
- Identifies and documents:
 - Multiple potential damage mechanisms
 - Special inspection needs (such as deadlegs, mix points or high risk equipment)
 - Process treatment and monitoring programs, chemical injection, water wash and fouling, etc.

TML/CML Analysis Conclusions

- User must consider:
 - Inherent thickness measurement error with or without a qualified procedure
 - Expected wall loss rate being measured (compared to UT accuracy)
 - Inspection intervals for wall loss detection
- Improved quality and accuracy of thickness measurements are needed to improve analysis capability
- Criteria provided to inspectors before field measurements are taken could significantly improve data quality
- More analysis and trending is necessary to understand the data and define requirements for improving TML inspection quality



Lynne Kaley, P.E.

Phone: 281-283-6502 • email: lckaley@equityeng.com

2625 Bay Area Blvd. • Suite 325

Houston, TX 77058 USA

Phone: 281-480-0556 • Fax: 281-480-2063

www.equityeng.com